

# EU DECLARATION OF CONFORMITY



Serial numbers are recorded at Clydesdale Ltd for traceability  
We declare that the PPE described hereafter:

## **Clydesdale NOAH SR Garments -**

Product Code	EN 61482-1-1, Arc Rating	EN 61482-1-2, Arc Class	EN ISO 11612, Flame resistance	Description
CLY 573 048 xxx	48 cal/cm <sup>2</sup> ATPV 43 cal/cm <sup>2</sup> ELIM	2	A1, B1, C1, E3, F1	NOAH SR Bib and Brace
CLY 574 048 xxx	48 cal/cm <sup>2</sup> ATPV 43 cal/cm <sup>2</sup> ELIM	2	A1, B1, C1, E3, F1	NOAH SR Jacket

This declaration is issued under the sole responsibility of the manufacturer.

The PPE described above is in conformity with the provisions of EU Personal Protective Equipment Regulation (“PPER”) 2016/425 as demonstrated by conformance to the PPER’s Essential Health and Safety Requirements and also with the following harmonised standards, specifications and test methods:

EN ISO 13688 : 2015

EN ISO 11612:2015

IEC 61482-2:2009

EN 61482-1-1:2019

EN 61482-1-2:2014

Is identical to the PPE on which EU type examination (Module B) 523772/1 was originally performed by notified body 0338, BTTG which has been transferred to the EU and is now held by:

Notified body 2895

Shirley

Port Tunnel Business Park

Office 13, Unit 21

Dublin 17, ROI

Is subject to the conformity assessment set out in Module D of the PPER under the surveillance of:,

Notified body 2895

Shirley

Port Tunnel Business Park

Office 13, Unit 21

Dublin 17, ROI

Is fitted with a unique serial number that is traceable in accordance with requirements of the PPER

A handwritten signature in black ink, appearing to read 'David Sample', is written over a faint, larger version of the same signature.

David Sample

Managing Director

Clydesdale Ltd.

15<sup>th</sup> November 2023 – Revision 5

# UKCA DECLARATION OF CONFORMITY



Serial numbers are recorded at Clydesdale Ltd for traceability  
We declare that the PPE described hereafter:

## **Clydesdale NOAH SR Garments -**

Product Code	EN 61482-1-1, Arc Rating	EN 61482-1-2, Arc Class	EN ISO 11612, Flame resistance	Description
CLY 573 048 xxx	48 cal/cm <sup>2</sup> ATPV 43 cal/cm <sup>2</sup> ELIM	2	A1, B1, C1, E3, F1	NOAH SR Bib and Brace
CLY 574 048 xxx	48 cal/cm <sup>2</sup> ATPV 43 cal/cm <sup>2</sup> ELIM	2	A1, B1, C1, E3, F1	NOAH SR Jacket

This declaration is issued under the sole responsibility of the manufacturer.

The PPE described above is in conformity with the provisions of PPE Regulations 2016/425 as brought into UK law and amended. PPE conformity is demonstrated by conformance to the Essential Health and Safety Requirements and also with the following standards, specifications and test methods:

BS EN ISO 13688 : 2013

BS EN ISO 11612:2015

IEC 61482-2:2009

BS EN 61482-1-1:2019

BS EN 61482-1-2:2014

Is identical to the PPE on which EU type examination (Module B) 523772/1 was performed by:

Approved body 0338

BTTG certification services

Unit 14

Wheel Forge Way, Trafford Park

Manchester M17 1EH

Is subject to the conformity assessment set out in Module D of the PPER under the surveillance of:,

Approved body 0338

BTTG certification services

Unit 14

Wheel Forge Way, Trafford Park

Manchester M17 1EH

Is fitted with a unique serial number that is traceable in accordance with requirements of the PPER

A handwritten signature in black ink, appearing to read 'David Sample', is written over a faint, stylized line.

David Sample

Managing Director

Clydesdale Ltd.

15<sup>th</sup> November 2023 – Revision 5